



A P P R O V A L S ®

Certificate of Suitability

* Addendum *

Certificate No.: SAA181121

Date of Issue: 8 May 2018

Class Description: Non-Declared

Product Description: Hybrid Inverter

Additional Models

Description

LXP-4K Hybrid

Input: 550Vdc Max, MPP voltage range 120-500Vdc 2×11A, I_{sc} PV 13.7A
Grid: 230V~ 50Hz 20A Max 4000VA
Battery: 40-60Vdc, charge/discharge current 66/66A, charge/discharge power 3600W
EPS output: 230V~ 50/60Hz 13A 3000VA

LXP-4.6K Hybrid

Input: 550Vdc Max, MPP voltage range 120-500Vdc 2×11A, I_{sc} PV 13.7A
Grid: 230V~ 50Hz 25A Max 4600VA
Battery: 40-60Vdc, charge/discharge current 66/66A, charge/discharge power 3600W
EPS output: 230V~ 50/60Hz 13A 3000VA

LXP-5K Hybrid

Input: 550Vdc Max, MPP voltage range 120-500Vdc 2×11A, I_{sc} PV 13.7A
Grid: 230V~ 50Hz 25A Max 5000VA
Battery: 40-60Vdc, charge/discharge current 66/66A, charge/discharge power 3600W
EPS output: 230V~ 50/60Hz 13A 3000VA


For and on Behalf of
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:
www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 09-05-18 181121/2a
Correction to Description